

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20242210  
Address: 1020 NW PRYOR RD, Unit:G, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Robb Popp	Failed	Friday, September 27, 2024

Informational:

1	Misc	5' welded roof transition piece approved on ground
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	Correct pinhole in welded connection to captive air system at SE corner
---	-----------------------------	---

**Comments:**