

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20226232  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Friday, September 27, 2024

Corrective Action Required:

1	FIRST FLOOR	*****AREAS APPROVED TO COVER: -Entry canopy ok to cover Additon complete except as noted: *AHU -Address duct penetration/ complete firewall  **Existing side: 1E-314-seal penetrations 300C-seal penetrations and label firewall 1E-315-Label firewall 1E-313-seal penetrations and label firewall
---	-------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	SECOND FLOOR	Above-ceiling OK below: **Addition Complete
---	--------------	------------------------------------------------

Corrective Action Required:

3	THIRD FLOOR	*****AREAS APPROVED TO COVER: Soffits at 3E-355, 346, 338, 241, 244, 306 UNITS 300A, 304-320, 360-367,335-349, 212, 213, 259-261, 246-258, 268-273, 214-219, 222, 224, 100a
---	-------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

-Seal penetrations and REMOVE TILE FOR INSPECTION

**Comments:**