CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 FAX (816) 969-1201 (816) 969-1200

Temporary Certificate of Occupancy

Permit #: PRRES20241361

Address: 3228 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

Inspected On: Friday, September 27, 2024

Inspected By: Development Center

Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Inspector: Date:

Occupancy Inspection - Codes Shawn Hoffman Ready for Temp CO Friday, September 27,

Residential 2024

Corrective Action Required:

Misc -sod

-splash blocks and sump pump discharge to extend 36" from foundation

-will check water meter at time of sod

Comments: