

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242368
Address: 1629 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, September 27, 2024

Corrective Action Required:

1	Misc	Garage portal frame okay Front porch roof framing okay
---	------	---

HOME NOT READY FOR INSPECTION
List incomplete (garage only inspected)
Complete list before calling for re inspection

- fire block hvac chase to ceiling space
- secure electrical in furr down in garage
- provide engineering for truss fix above bath 4
- fire block bath 4/garage wall to ceiling space

List still incomplete 09/23/24
REMOVED A FEW ITEMS, LIST NOT COMPLETE NOTHING INSIDE INSPECTED
9/27/2024

Comments: