

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242598  
Address: 3808 SW RAVENGATE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Not Ready	Friday, September 27, 2024

Informational:

1	Miscellaneous Correction	Exterior garage portal frame inspection passed and is okay to cover.
		This is a partial pass only

Corrective Action Required:

2	Miscellaneous Correction	House and truss plans are not on property at the time of inspection
		Not ready for inspection

**Comments:**