

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242075
Address: 2229 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, September 30, 2024

Corrective Action Required:

1	Misc	-Submit new revised plan with slide doors at rear of house. CSPF framing and nailing per revised plan -Block ceiling joist ends at basement curved stair wall -Provide a wall receptacle at wall space at left side of refrigerator -Fb garage duct/plumbing chase from joist space -Block ends of I joists above garage I beam -Header off joist at pantry duct chase -Protect wiring in master bedroom near entry door -Support ceiling framing above master bedroom
---	------	---

****OK TO INSULATE**

Comments: