

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231975  
Address: 1550 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Bobby Richest	Partial	Monday, September 30, 2024

Corrective Action Required:

1	Misc	5-21-24 BR Erosion control is up and working order.
		5-30-24 BR Erosion control is up and working order.
		6-3-24 BR Erosion control is up and working order.
		6-17-24 BR Silt fence needs to be repaired. There are several location along on the fence line that needs to be repaired.
		6-18-24 BR Silt fence has been repaired erosion control is up and working order.
		6-26-24 BR Erosion control is up and working order.
		7-3-24 BR Erosion control is up and working order.
		7-11-24 BR Erosion control is up and working order.
		7-17-24 BR Erosion control is up and working order.
		7-26-24 BR Erosion control is up and working order.

8-9-24 BR Erosion control is up and working order.

8-15-24 BR Silt fence needs to be repaired. There are several location along on the fence line that needs to be repaired.

8-26-24 BR Silt fence needs to be repaired. There are several location along on the fence line that needs to be repaired.

9-5-24 BR Erosion control is up and working order

9-11-24 BR Erosion control is up and working order.

9-17-24 BR Erosion control is up and working order.

9-30-24 BR Erosion control is up and working order.

**Comments:**