



**CITY OF LEE'S SUMMIT**  
**CODES ADMINISTRATION**

220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20100137  
**Address:** 1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086  
**Inspected On:** Friday, October 14, 2011  
**Inspected By:** John Borns  
**Expiration Date:** 10/27/2011 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Friday, October 14, 2011

**Corrective Action Required:**

1 MISC ELECT RECEPT REQUIRED AT ROOFTOP WITHIN 25" OF ALL EQUIPMENT

**Corrective Action Required:**

2 MISC BLACK IRON GAS PIPING AT ROOFTOP MUST BE PAINTED

**Corrective Action Required:**

3 MISC ROOFTOP EQUIPMENT TO BE DESIGNATED, WITH CORRESPONDING DESIGNATIONS REFLECTED IN ELECTRICAL PANEL

**Corrective Action Required:**

5 MISC DOWNSPOUTS NOT INSTALLED

**Corrective Action Required:**

7 MISC MAXIMUM HEIGHT OF BOTTOM OF MIRROR GLASS IN ACCESSIBLE RESTROOMS IS 40"

**Comments:**