

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Monday, September 30, 2024

Corrective Action Required:

1	Misc	<p>**Pre final walkthrough for 2nd floor addition: partial final</p> <ul style="list-style-type: none">-GFCIs not working in all front bathrooms-322 GFCI not working-202 Tighten loose receptacle-204, 205, 210 not done <p>**Pre final walkthrough for 3rd floor addition Women's health suite: partial final</p> <ul style="list-style-type: none">302-GFCI not working, provide GFCI protection at fridge303-GFCI not working, update plan to show no ADA compliance for clearance in front of WC324-GFCI not working-Complete above ceiling inspection at 101B, lobby-Remove tile and label firewalls-Complete elevator-Install drinking fountain-Provide min 27" knee clearance-Submit phasing and egress plan as previously requested-Complete all sinks and missing fixtures-Paint crosswalk to new parking lot
---	------	--

Comments: