

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241618
Address: 1801 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Not Ready	Monday, September 30, 2024

Corrective Action Required:

1	Miscellaneous Correction	1801 SW Hightown. Occupancy Properly install spark rings in kitchen backsplash Pig tail to disposal in not installed Garage to house door is missing its seal Fire block gaps in sheet rock in garage First riser height at stairs going from the main level up is not to code Gaps in attic access hatch in utility room No handrail is intro the basement No light receptacle at the bottom of the stairs to illuminate the stairs Gutters are not fully installed Sod, splash pads are sump pump extension are not installed Seal all exterior penetrations
---	--------------------------	---

Comments: