

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232726
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	Devon Perry	Passed	Monday, September 30, 2024

Informational:
1 Misc

9-26-24 DP. Met Matt with ESS onsite and pulled second set of water samples off of public water main and delivered them to Blue Valley Labs

9-30-24 DP. Both public samples have passed. The 12" south phase public water line can now be put in service.

Comments: