

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242856

Address: 1414 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1412 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Kyle Beard	Failed	Monday, September 30, 2024

Corrective Action Required:

1	Miscellaneous Correction	Both sides - Spots in the field are missing fasteners and fasteners are not installed on the edges along the rafters  Slid plywood in the attic back for a proper screw inspection
---	--------------------------	---

**Comments:**