

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20242441  
Address: 1220 NW MAIN ST, Unit:E, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Monday, September 30, 2024

Corrective Action Required:

1	Miscellaneous Correction	-Change address at main door to read 1220 E -Complete electrical at lobby -Ensure counter height at lobby is 34" aff max -Secure whip at water heater -Complete electrical at back warehouse -Mirror in warehouse restroom to be max 40" aff to reflective surface -Provide permanent tag at gas meter -Complete all corrections for LSFD **OK for furniture. DO NOT OCCUPY
---	--------------------------	---

Comments: