

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241421
Address: 1605 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, October 01, 2024

Corrective Action Required:

1	Misc	Outside only, no access
		<ul style="list-style-type: none">•pay outstanding fees•Final grading and sod•Installation of irrigation system•Provide splash pads•Provide gaurd front porch over 30" above grade•Provide ladder from Egress window basement•Secure electrical whip•With in 12" of disconnect•Sump discharge to be 36" away from foundation

Comments: