

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241619  
Address: 1805 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Not Ready	Tuesday, October 01, 2024

Corrective Action Required:

1	Miscellaneous Correction	1805 SW Hightown. Occupancy (2) Seal all sheet rock gaps for fire blocking in the garage Water meter in the front yard appears to be too high for plot elevation Sod and splash pads are not installed Seal all exterior penetrations Sump pump extension is not installed
---	--------------------------	---

Comments: