

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242368  
Address: 1629 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Shawn Hoffman	Failed	Tuesday, October 01, 2024

Corrective Action Required:

2	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.  - PROTECT FRONT OF LOT - REMOVE TRASH AND DEBRIS FROM LOT - TRIM TALL VEGETATION ON LOT
---	---------------------------------------	---

**Comments:**