

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221553
Address: 1616 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|-----------------------------|
| All Rough Inspection - Residential | Shawn Hoffman | Failed | Wednesday, October 02, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -address rear great room wall not framed to plans and address header size - (Engineer correction is strap from top plate to 18" below header, not done this way) -complete install fireplace (secure gas line) |
|---|------|---|

Comments: