CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244632

Address: 2778 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Erosion Control Shawn Hoffman Failed Wednesday, October

02, 2024

Corrective Action Required:

2 DCM6 ESC INSP REQUESTED INSPECTION(S) DENIED. STREET CLEAN UP REQUIRED DENIED STREET IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED

CLEAN UP INSPECTION(S) BEING PERFORMED.

- REPAIR SILT FENCE ON FRONT EAST SIDE OF LOT

- REMOVE TRASH AND DEBRIS FROM LOT

Comments: