

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242647
Address: 3224 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, October 02, 2024

Corrective Action Required:

1 Misc

- Lib in garage not installed to plans
- seal top plate penetration N bath one wall
- uncover covered patio for inspection
- fire block kitchen/ bath 2 wall to ceiling space
- bed 2 nail lib
- truss lateral bracing missing in multiple areas throughout
- fire block N rec room wall to ceiling space at furr down near window
- fire block W Rec room wall into furr down

Comments: