

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241421  
Address: 1605 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Wednesday, October 02, 2024

Corrective Action Required:

1	Misc	Outside only, no access
		<ul style="list-style-type: none"><li>•pay outstanding fees</li><li>•Final grading and sod</li><li>•Installation of irrigation system</li><li>•Provide splash pads</li><li>•Provide ladder from Egress window basement</li><li>•Secure electrical whip</li><li>•With in 12" of disconnect</li><li>•Sump discharge to be 36" away from foundation</li></ul>

Comments: