

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242598
Address: 3808 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Kyle Beard	Failed	Wednesday, October 02, 2024

Corrective Action Required:

1	Miscellaneous Correction	-Neutral in electrical panel is not connected -UFER is not utilized -14/2 wire in basement by HVAC in in a loop and not connected
---	--------------------------	---

Comments: