

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|------------|----------|-----------------------------|
| Rated Assembly Inspection | Robb Popp | Partial | Wednesday, October 02, 2024 |

Informational:

1 FIRST FLOOR

building A
Complete

Building B:

*Submit 3rd party approval for structural steel fireproofing

Building C:

-complete

Building D:

-complete

Building E-1st layer behind tubs

-RC at walls and ceilings except at garage 200

-1st and 2nd layer at firewalls excluding 204

Informational:

2 SECOND FLOOR

Building A:
Complete

Building B:

-complete

Building C:
Complete

Building D:
Complete

Building E:
-RC at walls and ceiling
-1st and 2nd layer at 2 hour walls
-Screw pattern at walls and ceiling except at elevator

Corrective Action Required:

3 THIRD FLOOR

Building A:
Complete

Building B:
Complete

Building C:
Complete

Building D:
Complete

Building E:
-1st and 2nd layer behind tubs and showers
-RC at units and corridors
-1st layer screw pattern

Informational:

4 FOURTH FLOOR

Building A:
Complete

Building B:
-Complete

Building C:
Complete

*Building D:
Complete

*Building E:
-1st layer at truss space separation wall D/E
-1st and 2nd Layer behind tubs
-1st layer at firewalls
-RC at units and corridors
-Screw pattern at walls and corridors except at elevator and firewall
-Screw pattern at units and corridors

Corrective Action Required:

5 ELEVATOR 1

*Elevator 1 in building A

| | | |
|-----------------------------|---------------|---|
| | | -Complete |
| Corrective Action Required: | | |
| 6 | STAIR TOWER 1 | *Stair A building A -Complete |
| Informational: | | |
| 7 | STAIR TOWER 2 | *Stair B in building B -Complete |
| Informational: | | |
| 8 | STAIR TOWER 3 | Stair 2B in building B -Complete |
| Informational: | | |
| 9 | STAIR TOWER 4 | *Stair D in building D -Complete |
| Informational: | | |
| 10 | STAIR TOWER 5 | Stair E building E -Complete |
| Informational: | | |
| 11 | ELEVATOR 2 | Elevator 2 in building C: -complete |
| Corrective Action Required: | | |
| 12 | ELEVATOR 3 | Elevator 3 in building E -complete at interior |

Comments: