CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20241421
Address:	1605 SW ARBORWAY TER, LEES SUMMIT, MO 64082
Inspected On:	Thursday, October 03, 2024
Inspected By:	Development Center
Expiration Date:	

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspe	ction:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential Corrective Action Required:		Mitchell Schwarz	Ready for Temp CO	Wednesday, October 02, 2024
1	Misc	Outside only, no access		
		 pay outstanding fees Final grading and sod Installation of irrigation system Provide splash pads Provide ladder from Egress window basement Secure electrical whip With in 12" of disconnect 		

•Sump discharge to be 36" away from foundation

Comments: