

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241067  
Address: 2087 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Robb Popp	Failed	Thursday, October 03, 2024

Corrective Action Required:

1	Misc	-Bond metallic gas piping to GES -CSST secured in joist space less than 3" to bottom of joists requires 16g striker plate -Seal through floor penetrations
---	------	--

**Comments:**