

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243956  
Address: 3221 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                         | Inspector:       | Outcome: | Date:                      |
|-------------------------------------|------------------|----------|----------------------------|
| <b>Sewer Service Inspection - R</b> | Mitchell Schwarz | Failed   | Thursday, October 03, 2024 |

Corrective Action Required:

|   |      |                                             |
|---|------|---------------------------------------------|
| 1 | Misc | clean out required every 100 feet from Main |
|---|------|---------------------------------------------|

**Comments:**