

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241487
Address: 3241 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, October 03, 2024

Corrective Action Required:

1	Misc	-address holes drilled to close to one another above pantry (provide engineering for fix) -2x6 wall at great room/ stairs not full height to plans -complete ufer ground -no gas line installed at time of inspection
---	------	--

Informational:

2	Misc	Missing erosion control and address. Inspection denied.
---	------	---

Comments: