

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242860

Address: 1438 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1436 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Kyle Beard	Failed	Thursday, October 03, 2024

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.  Clean gravel from the street and repair or replace silt fence at the front of the lot at the street that has been torn down and is no longer effective  Full erosion control measures must be in place and maintained until Cofo
---	---	--

**Comments:**