

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241800
Address: 3824 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, October 03, 2024

Corrective Action Required:

1	Miscellaneous Correction	3824 SW Ravengate. Occupancy (2)
		GFCI in basement by stairs is not working (Has a open ground)
		Sod, splash pads and sump pump extension are not installed

Comments: