

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241854  
Address: 3820 SW RAVENGATE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Devon Perry	Partial	Thursday, October 03, 2024

Informational:	
1      Misc	10-3-24 DP. Crew had formed the missed ADA ramp on the development. Running slopes were able to be in compliance. The cross slopes will be slightly above 3% at the existing sidewalk. Every thought was exhausted and the ADA ramp is being poured as well as it can get. Approved to pour

**Comments:**