

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240500
Address: 2535 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Thursday, October 03, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Not ready fee assessed on 7/10/24 has not been paid-Sidewalk and driveway not approved on record-Attach deck beam to each post with two 1/2" through bolts/washers/nuts or equivalent connections-Seal exterior light at walkup area-Install tamper-proof caps at AC valves-Provide sewer tracer wire port at grade-Garage door not self-closing-Support receptacle yoke in front bathroom-The box extension at switch boxes must be flushed to the combustible wall surface-Reposition the water heater so the PT discharge pipe is diverted away from framing-Exterior light at walkup area not working-Locate and make accessible the sewer clean out
---	------	--

Comments: