

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241135  
Address: 3249 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:       | Outcome:          | Date:                    |
|-------------------------------------------------|------------------|-------------------|--------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Mitchell Schwarz | Ready for Temp CO | Friday, October 04, 2024 |

Corrective Action Required:

|   |      |                                                                                      |
|---|------|--------------------------------------------------------------------------------------|
| 1 | Misc | *TCO EXTENSION LETTER UPLOADED, APPROVED FOR 30 DAY EXTENSION*                       |
|   |      | -pay all fees                                                                        |
|   |      | -sod                                                                                 |
|   |      | -splash blocks and sump pump discharge to extend 36" from foundation                 |
|   |      | -bring water meter well to grade (ensure 14"-18" from top of meter to well lid ring) |
|   |      | -bring valves tops to grade                                                          |

**Comments:**