

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231204  
Address: 2951 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector:    | Outcome: | Date:                    |
|----------------------------------|---------------|----------|--------------------------|
| <b>Sanitary Sewer - Air Test</b> | Bobby Richest | Partial  | Friday, October 04, 2024 |

Informational:  
1 Misc 10-3-24 BR Contractor preformed test MH -19/ MH-18, MH- 18/ MH- 17, MH-17/ MH-16, MH-16/ MH-15 pass

**Comments:**