



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114324, Building Permit - Commercial  
Address: 188 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Partial	Tuesday, October 18, 2011

Corrective Action Required  
1 MISC

HARD CEILING - INSPECTED:  
SOFIT-OVER SALES COUNTER/DISPLAY NITCH

<b>In-wall Inspection</b>	Mark Harding	Passed	Tuesday, October 18, 2011
---------------------------	--------------	--------	---------------------------

Partial Correction  
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL  
SYSTEMS AT FOLLOWING SPACES: 101; 102; 103;  
104;105;106;107;108.; 112;

<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Tuesday, October 18, 2011
----------------------------------	--------------	---------	---------------------------

Partial Correction  
1 MISC

OK TO TAPE, MUD, & FIRE-SEAL WHEN READY GWB  
INSTALLATION AT 1 HR FIRE-RATED WALLS @ FOLLOWING  
LOCATIONS: RM 104 COMPLETE

**Comments:**