

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241971
Address: 3828 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Friday, October 04, 2024

Corrective Action Required:

2	Miscellaneous Correction	3828 SW ravengate. Occupancy (2) Electrical in kitchen is not complete (now has a open ground) water meter appears to high for grade Sump pump extension is not installed Sod and splash pads are not installed
---	--------------------------	---

Comments: