

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242857

Address: 1420 SW WINTHROP TER, LEES SUMMIT, MO 64081
1418 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Shawn Hoffman	Failed	Friday, October 04, 2024

Corrective Action Required:

1	Miscellaneous Correction	Both sides
---	--------------------------	------------

-- Screws are not set against the sheetrock.
Fully seat all screws to sheetrock to secure sheetrock against studs.

Reschedule when complete. This can be inspected during the all-rough.

Comments: