

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240929
Address: 2319 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|------------------|----------|--------------------------|
| Erosion Control | Mitchell Schwarz | Failed | Friday, October 04, 2024 |

Corrective Action Required:

| | | |
|---|---------------------------------------|---|
| 2 | DCM2 ESC DEFICIENT INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. |
|---|---------------------------------------|---|

Corrective Action Required:

| | | |
|---|----------------------------|---|
| 3 | DCM3 ESC REQUIRED 2 DAY | EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -repair silt fence -clean street -maintain overgrown vegetation |
|---|----------------------------|---|

Comments: