



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20110168, Building Permit - Residential
Address: 3408 SW LOIS LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Final - Residential	Mike Copeland	Failed	Tuesday, October 18, 2011

Corrective Action Required

1	SP 7-1011 FENCING	SWIMMING POOLS. A. The area which a swimming pool, sauna, hot tub, or jacuzzi is located shall be entirely enclosed and separated from adjoining property by a protective fence or other permanent structure not less than four (4) feet in height, measured from grade. The enclosure shall be so constructed that a sphere four (4) inches in diameter cannot pass through. Fence posts shall be decay or corrosion- resistant and shall be set in concrete bases. Such protective enclosure shall be provided with gates equipped with self-closing and self-latching devices placed at the top of the gate;
---	-------------------	---

FENCE ON PROPERTY IS NOT SELF CLOSING SELF LATCHING
AS DESCRIBED ABOVE.
PROVIDE CLOSER AND CALL FOR RE-INSPECTION.

Comments: