

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243664
Address: 3009 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Mitchell Schwarz	Failed	Friday, October 04, 2024

Corrective Action Required:

1	Misc	-sheet rock under stairs area -afci protection for wet bar, fireplace,dry bar -add box extenders to outlets in backsplash
---	------	---

Comments: