

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Bobby Richest	Partial	Friday, October 04, 2024

Informational:
1 Misc

10-3-24 BR Contractor preformed test on MH -16/ MH- 17 pass, MH-17/ MH-18 pass, MH-18 / MH-19 pass.

10-4-24 BR Contractor preformed test on MH -16 / MH -15, MH -15 / MH -14, MH - 14/ MH - 13 pass.

Comments: