

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231204  
Address: 2951 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	Bobby Richest	Partial	Friday, October 04, 2024

Informational:

1	Misc	10-3-24 BR Contractor preformed test MH -19/ MH-18, MH- 18/ MH- 17, MH-17/ MH-16, MH-16/ MH-15 pass
		10-4-24 BR Contractor preformed test MH - 15/ MH -14, MH - 14/ MH - 13 pass.

**Comments:**