

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234906
Address: 2307 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Devon Perry	Partial	Friday, October 04, 2024

Corrective Action Required:

1	Misc	5-16-24 Dustin A, Sw is poured, white cure was not applied correctly
Informational:		
2	Misc	10-4-24 DP. This is for the public sidewalk behind 2307 SW Serena PL. SW was formed, aggregate was compacted, cross slopes were in compliance but conditions can change. Approved to pour.

Comments: