

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244953
Address: 1909 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Kyle Beard	Not Ready	Monday, October 07, 2024

Corrective Action Required:

1	Miscellaneous Correction	Two joints at the S/W corner of the basement do not have 24 inches of steel overlap One section of the basement east wall is missing its form board No improvements were made Not ready for re inspection
---	--------------------------	--

Comments: