

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20243061  
Address: 2070 NW LOWENSTEIN DR, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Failed	Monday, October 07, 2024

Informational:  
1 Misc Hard lids at entry and bathroom approved  
Corrective Action Required:  
2 Miscellaneous -Secure MC within 12" of boxes  
Correction

**Comments:**