

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242210
Address: 1020 NW PRYOR RD, Unit:G, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-----------------------------|------------|----------|--------------------------|
| Hood/Duct Inspection | Robb Popp | Partial | Monday, October 07, 2024 |

Informational:
1 Misc -5' welded roof transition piece approved on ground
-welded connection to captive air system Ok
-1st layer at welded connection ok

Comments: