

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242647
Address: 3224 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, October 07, 2024

Corrective Action Required:

1	Misc	-seal top plate penetration N bath one wall -fire block kitchen/ bath 2 wall to ceiling space(seal penetrations) -truss lateral bracing missing in multiple areas throughout (B4, check others)
---	------	---

Comments: