

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Partial	Monday, October 07, 2024

Corrective Action Required:

1	Misc	Main floor-OK to cover: -Roof-ceiling assembly -Kitchen, manager's office and adjacent office, front entry soffit -Rest of upper floor, except elevator, restrooms, and work-break room
---	------	--

Shear wall screw pattern at great room-OK

Corrective Action Required:

2	LOWER LEVEL	-Provide new revised plan -Submit engineer repair for roof and floor trusses -Underneath all beam point load, install equal number of studs to the stud pack in truss space and in wall down to footing
---	-------------	---

Comments: