

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244502
Address: 2027 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Mitchell Schwarz	Partial	Monday, October 07, 2024

Corrective Action Required:

1	Misc	-perimeter bonding complete -Water bond at skimmer
---	------	---

contractor states "removing conduit underground not in compliance and not inspected"

Comments: