

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20226232  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Monday, October 07, 2024

Informational:	
1	Misc
	Partial occupancy for ASC Expansion: **OK to occupy the following areas: -1st floor addition side only to column line BB.5 on A221a of approved plans -2nd floor addition side only to column line BB.5 except as noted in corrections -3rd floor Women's Health Suite and corridor 1E-200J only, as noted in Blue on Phase map provided on 10/2/24 (See document on Portal)

Informational:	
2	Misc
	Partial occupancy for existing side renovations: **OK to occupy the following areas: -1E-315c, 1E-314, 1E-313 and corridor 300C approved to occupy
Corrective Action Required:	
3	Miscellaneous Correction
	-Provide State Elevator Certification for new East elevator and existing South elevator -Paint crosswalks to new parking lot -Provide documentation for field installed fire rating at doors in Soiled Rm 3E-322 -Provide rail or barrier at under stair space less than 80" vertical clearance per A117.1 Sec. 307.4 at both stairwells -Open hand holes in light poles for inspection -Remove construction water meter at job trailer

**\*\*2nd floor addition:**  
-Rm 204, 205 (exam 4 & 5) not complete

**Comments:**