

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241833  
Address: 2147 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, October 08, 2024

Corrective Action Required:

1 Misc

- fireblock E kitchen wall to ceiling space at pantry
- minimum 3 studs at all exterior wall corners. Check throughout
- add fire blocking every 10' see basement W wall(must be of approved fire blocking materials- check throughout)
- seal penetrations in fire blocking and top plate in bed 4 closet

**Comments:**