

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241221
Address: 3216 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|-------------------|---------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Ready for Temp CO | Tuesday, October 08, 2024 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -pay all fees -splash blocks -siding from grade on S side of home not in compliance -establish vegetation in disturbed green space behind lot |
|---|------|--|

Comments: